



- ADDITIONAL NOTES:**
- ① ALL CIRCUIT BREAKERS, ISOLATORS AND EARTH LEAKAGE TO BE TYPE 2 CURVE AND EQUIPMENT TO BE CBL.
 - ② WEATHERPROOF FLOOR STANDING 3CR12 DB.
 - ③ DB TO BE BOTTOM ENTRY FOR CABLES.
 - ④ BUSBAR TO BE SHROUDED
 - ⑤ EARTH & NEUTRAL BAR TO BE EASY ACCESSIBLE.
 - ⑥ SUFFICIENT SPACE REQUIRED FOR SAFE ACCESS FOR REWIRING.
 - ⑦ ALL OUTGOING CIRCUIT BREAKERS TO BE LABELED WITH DESCRIPTION OF SERVICES AND CIRCUIT NOS. AS PER DRAWING.
 - ⑧ KIOSK TO BE 3CR12 STEEL VANDAL PROOF WITH LOCKABLE DOOR, ORANGE IN COLOUR
 - ⑨ eTHEKWENI DIRECT METER TO BE SUPPLIED BY eTHEKWENI ELECTRICITY.

FIELD	CIRCUIT No./ PHASE	DESIGNATION	WIRING	LOAD (AMPS)	No. OF POINTS	CABLE No.
		INCOMER FEED FROM ETHEKWENI ELECTRICITY		210		
		DB-G1 COMMON AREA MAIN BOARD No.DB-G1	1x10mm ² 2 CORE Cu PVC SWA PVC ECC CABLE	60	10	
		COMMON AREA MAIN BOARD DB-G2	1x10mm ² 2 CORE Cu PVC SWA PVC ECC CABLE	10		
		POLE LIGHTS	4mm ² 4 CORE Cu PVC SWA PVC ECC CABLE	-		
		POLE LIGHTS	4mm ² 4CORE Cu PVC SWA PVC ECC CABLE	-		
		SPARE		-		
		SPARE		-		
		METERING PANEL No.1	25mm ² 4 CORE Cu PVC SWA PVC ECC CABLE	40		
		METERING PANEL No.2	25mm ² 4 CORE Cu PVC SWA PVC ECC CABLE	40		
		METERING PANEL No.3	25mm ² 4 CORE Cu PVC SWA PVC ECC CABLE	40		
		METERING PANEL No.4	25mm ² 4 CORE Cu PVC SWA PVC ECC CABLE	40		
		METERING PANEL No.5	25mm ² 4 CORE Cu PVC SWA PVC ECC CABLE	40		
		METERING PANEL No.6	25mm ² 4 CORE Cu PVC SWA PVC ECC CABLE	40		

NOT WITHSTANDING ANYTHING TO THE CONTRARY, ALL RIGHTS RESERVED, NO PART OF THIS DRAWING MAY BE REPRODUCED IN ANY MATERIAL FORM (INCLUDING PHOTOCOPIING OR STORING IN ANY MEDIUM OR BY ELECTRONIC MEANS WHETHER OR NOT TRANSIENTLY OR INCIDENTALLY TO SOME OTHER USE OF THIS DRAWING) AND ALSO, THIS DRAWING MAY NOT BE USED FOR ANY PURPOSE OR REASON OTHER THAN FOR WHICH IT WAS ORIGINALLY ISSUED, WITHOUT THE WRITTEN PERMISSION OF IBUYA CONSULTING ENGINEERS.

		ENGINEER	DRAWN	DATE:	SCALE:	CHKD.	TITLE
		S.Nzama	C.H	June 2014	n.t.s PAPER SIZE: A3		Community Residential Units KZN
		PROJECT No.	DRAWING No.	SHEET:	REV.		DRAWING TITLE:
			14020	401	1 of 1	0	Main LV Kiosk Single Line Diagram
REV	DESCRIPTION	BY	DATE	CHKD.	FILE Name : 14020_401_0	LYr: 01:1A3	